A DIVISION OF GENLYTETHOMAS GROUP LLC


GENERAL DESCRIPTION

The CMF/TMF Series provides a field tested. reliable source of egress lighting for the commercial and light industrial markets. Available in a wide range of battery wattages, these units incorporate high performance electronics in a classically designed package.

ILLUMINATION

Illumination is accomplished with lamp heads mounted on the top of the unit. The CMF/TMF Series can accommodate up to three lamps heads. Most often specified is Chloride's round thermoplastic tungsten lamp head.

DIMENSIONS



CATALOG NO.:

CMF/TMF Series

Steel Emergency Lighting Units

6 and 12 Volt. 18 to 250 Watts **Lead Calcium or Nickel Cadmium Battery**

Housing

Constructed of 20 gauge (18-100w) or 18 gauge (125-250w) steel with a white corrosion-resistant, epoxy

Available with a wide range of fully adjustable PAR 36 sealed beam tungsten or halogen; wedge base tungsten or halogen lamp heads.

Easily mounted with key hole slots or shelf mounting. Universal J-box mounting on 18 watt to 50 watt cabinets.

Includes a low profile test switch on the side of unit.

ELECTRONICS

120/277 VAC dual voltage input with surge-protected, solidstate circuitry provides for a reliable charging

Lead calcium units utilize a solid-state, fully automatic, voltage regulated charger.

Nickel Cadmium units utilize a solid-state, constant current

High capacity units operate a complete line of remote

Charging system is complete with low voltage disconnect, AC lockout, brownout protection, AC indicator lamp and test switch.

Optional ACCU-TEST Self Diagnostics includes an automatic 3 minute discharge test every 30 days. A manual test is available from 1 to 90 minutes.

BATTERY

Maintenance free, sealed lead calcium battery has an estimated service life of 5 years, and an operating temperature range of 65°F (19°C) to 85°F (30°C)

Maintenance free, sealed nickel cadmium battery has an estimated service life of 10 years, and an operating temperature range of 20°F (-7°C) to 95°F (35°C)



SHOWN: CMF50WWTB2

CODE COMPLIANCE

UL 924 listed

NFPA 101

NEC, BOCA and OSHA illumination standard Chicago Approved City Plan No. 9187E, 9188E

PERFORMANCE

Input power requirements

18 - 100 watt units - 0.18 amps, 18 watts (120 VAC) 125 - 250 watt units - 0.58 amps, 60 watts (120 VAC)


WARRANTY

Three year full electronics warranty

One year full plus four year prorated lead calcium battery warranty

Five year full plus five year prorated nickel cadmium battery warranty

ORDERING INFORMATION



WTB

LAMP **HEADS**

6 Volt, Tungsten, Wedge Base WTA = 5.4 Watt WTD = 7.2 Watt

WTB = 9 Watt 6 Volt, Tungsten, Sealed Beam

WY = 8 Watt WA = 18 Watt WL = 25 Watt

WC = 30 Watt 12 Volt, Tungsten, Wedge Base WTC = 9 Watt

WTE = 12.5 Watt WTF = 17.9 Watt 12 Volt, Tungsten, Sealed Beam

WNY = 12 Watt WE = 18 Watt

WG = 30 Watt



HEADS

FACTORY INSTALLED # OF

3 = Three 2 = Two1 = 0neBlank = No Heads

ACF2 = 277 VAC Fuse ACP1 = 120 VAC Power Switch ACP2 = 277 VAC Power Switch AD = ACCU-TEST Self-Diagnostics ADAL = ACCU-TEST with Alarm

A = Ammeter 2

ACF1 = 120 VAC Fuse

ADTD = ACCU-TEST with Time Delay 4 DCP = DC Power Switch 3

OPTIONS

EX = Special Input Transformer 1 (Specify voltage & frequency) I = Factory Installed Lamp Heads (18 - 50 W only)

TD1 = 120 VAC Time Delay ² TD2 = 277 VAC Time Delay ²

V = Voltmeter 2



MLSHELFW = Mounting Shelf 18 - 50W MJSHELF = Mounting Shelf 75 - 100W MXSHELF = Mounting Shelf 125 - 250W

NOTES: 1) Some option configurations may impact UL listing. Consult factory for specifics. 2) Not available with AD, ADAL, or ADTD options. 3) Consult factory above 50 watt capacity. 4) 15 minute delay.

Specification Data for CMF/TMF Series Steel Emergency Lighting Units


Housing

20 gauge (18-100w) or 18 gauge (125-250w) steel housing with epoxy powder coat finish. White finish standard, tan finish optional.


Provides installation flexibility with its J-box mounting pattern (18 - 50 watt units) and keyhole slots. Unit can also be shelf-mounted.

The suggested lamp head is the round thermoplastic lamp head with either wedge base or Par 36 sealed beam tungsten lamps. To order lamp heads other than the suggested head, refer to the options and accessories section.

LAMP HEAD PHOTOMETRICS (For WTB, suggested head for CMF/CNM up to 50w)



(For WTC, suggested head for TMF/TNM up to 50w)



ELECTRONICS

120/277 VAC dual voltage input with surge-protected, solid-state charging circuitry provides for a reliable charging system. The charging system is furnished with low voltage disconnect, AC lockout, brownout protection, AC indicator lamp and test

The low voltage disconnect (LVD) feature will disconnect the battery prior to an unacceptable deep discharge, but not before the required 90 minute emergency operation.

The AC lockout feature prevents battery drain prior to the initial energizing of utility power, and allows the installer to complete all wiring and electrical connections without energizing the emergency circuit.

The brownout protection circuitry will automatically switch the unit into the emergency mode if the utility voltage sags below 20% of nominal.

Battery charging circuitry is entirely solid-state, and utilizes a constant current charger for nickel cadmium battery units. A fully automatic, voltage regulated charger is used for lead calcium battery units. Battery recharge time after full discharge is less than the required UL 924 standard.

Line sensitive electronics cause an instantaneous transfer to battery power if utility power is lost, or a brownout condition is detected. When line voltage is

present and stabilized, the transfer **OPERATION** circuitry switches back to normal operation and begins recharging the battery. The transfer circuitry can be tested via a momentary test switch located on the housing.

CODE COMPLIANCE

The CMF/TMF Series meets or exceeds all performance standards as required by UL 924, NFPA 101, NEC, BOCA and OSHA. In addition, the CMF and TMF are Chicago Approved -- City Plan No. 9187E, 9188E.

SELF-DIAGNOSTICS

The ACCU-TEST Self-Diagnostics option conducts automatic and manual tests, and indicates real time status of the lamp, battery and charger via LED indicator lamps. Automatic tests include: Systems analysis every 10 seconds, with actual load tests performed for a 3 minute duration every 30 days. A manual test is available from 1 to 90 minutes.

BATTERY

Maintenance free, sealed nickel cadmium or lead calcium batteries are available.

Standard sustained emergency operation is for 90 minutes with the illumination source providing full light output.

The suggested operating temperature range for nickel cadmium batteries is 20°F (-7°C) to 95°F (35°C), and battery has an expected service life of 10 years. The suggested operating temperature range for sealed lead calcium batteries is 65°F (19°C) to 85°F (30°C), and the battery has an expected service life of 5 years.

PERFORMANCE

Input power requirements

18 - 100 watt units - 0.18 amps, 18 watts (120 VAC) 125 - 250 watt units - 0.58 amps, 60 watts (120 VAC)

DC Voltage	Unit	Suggested Lamp Head	Watts to 87½ of Rated Voltage*				
voitage	Onit	Lamp Hoad	1½ hrs.				
6	CMF18W	WTB	18	13.5	7		
	CMF25W	WTB	25	19	9.5	_	
	CMF36W	WTB	36	27	14	7.2	
	CMF50W	WTB	50	37.5	19	10	
	CMF75W CMF100W	WA WL	75 100	56.5 75	28.5 38	15 20	
	CMF100W CMF125W	WL WL	125	94	47.5	21.5	
	CNM25W	WTB	25	19	9.5	21.3	
	CNM50W	WTB	50	37.5	19	10	
12	TMF36W	WTC	36	27	14	7.2	
	TMF50W	WTC	50	37.5	19	10	
	TMF100W	WK	100	75	38	20	
	TMF150W TMF250W	WK	150	112.5 187.5	72	25.5	
	TNM25W	WK WTC	250 25	187.5	95 9.5	50	
	TNM50W	WTC	50	37.5	19	10	
	TNM75W	l WE	75	56.5	28.5	15	
	TNM100W	WK	100	75	38	20	
	TNM125W	WK	125	94	47.5	21.5	
	TNM150W	WK	150	112.5	72	25.5	
						•	

SUGGESTED SPECIFICATION

Furnish and install Chloride Systems emergency lighting unit model ______. The unit shall be constructed to meet Underwriter's Laboratories, Inc. Standard #924 and the National Electrical Code (NEC).

INSTALLATION AND OPERATION - Unit shall be easily field connected to a 120 or 277 VAC. 60 hertz, unswitched power source. Installation must comply with the NEC as well as other applicable codes. Upon utility power failure or brownout, the unit shall automatically transfer to battery power and maintain the required illumination level for a minimum period of 90 minutes. Upon restoration of utility power, the charger shall restore the battery to full charge within UL 924 requirements following a rated discharge of not more than 90 minutes.

CHARGER - Product shall utilize either a constant current (nickel cadmium) or fully automatic, voltage regulated (lead calcium) charging system. The charging system shall maintain the battery at full capacity without the need for periodic exercising or equalization. The following features shall be standard: Low voltage disconnect (LVD), brownout protection and AC lockout.

BATTERY - The battery shall be either a maintenance free, sealed nickel cadmium or lead calcium battery. The nickel cadmium battery shall utilize sintered plate construction and polypropylene separators for trouble-free operation in ambient temperatures up to 95°F (35°C). The lead calcium battery shall provide trouble-free operaation in temperatures up to 85°F (30°C). Nickel cadmium batteries shall be supplied with a five year full warranty, and sealed lead calcium batteries shall be supplied with a one year full warranty.

HOUSING - The unit housing shall be constructed of 20 gauge (18-100w) or 18 gauge (125-250w) steel and shall have an epoxy powder coat white finish.



